

HEATSTRIP · ACCESSORY SHEET

Max 2400 W recess enclosure

An enclosure matching the specified heater, to recess its body into the ceiling while keeping the radiant face directed towards the occupied area.



Associated heater

Max 2400 W

Shop reference	THX-AC-030
Manufacturer's reference	THXAC-030
Compatible heater	Max 2400 W
Overall dimensions	980 × 180 × 290 mm
Ceiling cut-out	935 × 250 mm

The manufacturer's reference identifies the enclosure; the shop reference is the one on your Radiant Heater product page. The dimensions above distinguish the enclosure's overall size from the cut-out.

HEATSTRIP · THX-AC-030

Preparing and using this accessory

Ceiling integration

The heater fits inside the enclosure. Its radiant face remains visible and directed towards the occupied area. The support must carry the weight of both enclosure and heater.

Prepare the recess

Prepare a 935 × 250 mm cut-out and check the space for the 980 × 180 × 290 mm enclosure. Keep the free space needed for mounting and connection.

The recess installation manuals specify a 50 mm ventilation space behind the enclosure. This is additional to its overall depth; keep insulation and cables away from the hot body.

Mounting steps

1. Prepare a load-bearing structure and an opening matching the model. 2. Secure the enclosure to the structure with suitable anchors. 3. Fit the compatible heater and lock its connections. 4. Arrange the electrical connection, check all fastenings and keep the clearances unobstructed.

Maintenance

Disconnect the heater's power supply and let the whole assembly cool before cleaning. Use a soft cloth and mild detergent, without abrasives or a high-pressure jet.

YOUR RADIANT HEATER CONTACT

+33 (0)4 23 15 02 48
radiant-heater.com/contact
Accessory reference: THX-AC-030.